

October 11, 2022

Todd Peterson  
Montana-Dakota Utilities  
400 N 4th Street  
Bismarck, ND 58501

**Re: Lewis & Clark Station, Notification of Statistically Significant Levels Above Ground Water Protection Standards (Spring 2022)**

Dear Mr. Peterson:

The Spring 2022 assessment monitoring event at Lewis & Clark Station has resulted in detections of lithium at statistically significant levels above ground water protection standards (GWPS) established under the CCR Rule (40 CFR 257, Disposal of Coal Combustion Residuals From Electric Utilities), § 257.95 (h). The data supporting this determination were received July 14, 2022.

Sincerely,

A handwritten signature in blue ink, appearing to read "Paul T. Swenson".

Paul T. Swenson, P.E.