



# Montana-Dakota Utilities Co.

400 N 4<sup>th</sup> Street  
Bismarck, ND 58501

## State of Wyoming Electric Rate Schedule

W.P.S.C. Tariff No. 2  
Original Sheet No. 80

### PARALLEL GENERATION GENERAL RULES Rate 59

Page 1 of 3

#### GENERAL RULES FOR PARALLEL GENERATION:

1. The interconnection between the utility and the qualifying facility will be limited to the service voltage and phases available at the qualifying facility. If different voltages or phases are required, the necessary changes will be provided by the qualifying facility.
2. The power factor and frequency of the qualifying facility shall be such as to not adversely affect the utility system. If corrective devices are required, they will be provided by the qualifying facility.
3. Fault protection equipment shall be provided by the qualifying facility. The utility and qualifying facility shall coordinate protective devices in order to limit damage to each system.
4. The qualifying facility's interconnection shall meet the requirements of local, state and federal codes.
5. The owner of the qualifying facility shall submit equipment specifications as requested by the utility prior to owner's installation of such equipment to assure compatibility and coordination with the utility system.
6. The owner of a qualifying facility will be requested to curtail, interrupt or reduce deliveries of electric energy, in order that the utility may construct, install, maintain, repair, replace, remove or inspect any of its equipment or any part of its system, or if it determines that curtailment, interruption or reduction of delivery is necessary because of safety, emergencies, forced outages or operating conditions on its system. Except in case of emergency, in order to minimize operating problems, the utility and qualifying facility shall give the other reasonable prior notice of any curtailment, interruption or reduction of delivery and its probable duration.
7. The Company reserves the right for periodic inspection of safety devices which are part of the interconnection. This would not affect the

**Date Filed:** June 30, 2025

**Effective Date:** Service rendered on and  
after April 1, 2026

**Issued By:** Travis R. Jacobson  
Vice President – Regulatory  
Affairs

**Docket No.:** 20004-174-ER-25  
Record No. 17880

PUBLIC SERVICE COMMISSION  
APPROVED

EFFECTIVE: **April 1, 2026**

DOCKET NO. **20004-174-ER-25**  
STATE OF WYOMING



# Montana-Dakota Utilities Co.

400 N 4<sup>th</sup> Street  
Bismarck, ND 58501

## State of Wyoming Electric Rate Schedule

W.P.S.C. Tariff No. 2  
Original Sheet No. 80.1

### PARALLEL GENERATION GENERAL RULES Rate 59

Page 2 of 3

responsibility of the qualifying facility to assure the operating safety of the equipment on its side of the interconnection point.

8. The Company reserves the right to disconnect any facility that has interconnected without utility authorization.
9. The Company has the right to disconnect and lock-out a qualifying facility's generating equipment with due notice whenever it has been determined that harmonics are being produced or other factors are present which would interfere with communications or otherwise cause degradation of service to other customers. If, in the judgment of the utility, an unsafe condition is created on the utility system by the operation of the qualifying facility, the utility shall have the right to disconnect the facility until the cause of such condition is eliminated.
10. In the event of a utility system outage or interruption of service, a qualifying facility's generator shall be capable of automatically disconnecting itself to prevent the utility's line from being energized. Also, a qualifying facility's system shall not be capable of energizing the utility's line when that line is deenergized.
11. A manually operated generator disconnect switch, provided by the owner of a qualifying facility, shall be accessible to utility personnel at all times. Such a switch would be used whether or not the owner is present to remove the qualifying facility's generator from the line in an emergency situation as determined by utility system conditions.
12. The owner of a qualifying facility shall maintain operating communications with the utility for facilities with a capacity of more than 100 Kw or as requested. Operating communications shall include, but not be limited to, system paralleling or separation, scheduled and unscheduled shutdowns, equipment clearances and load reports.

**Date Filed:** June 30, 2025

**Effective Date:** Service rendered on and  
after April 1, 2026

**Issued By:** Travis R. Jacobson  
Vice President – Regulatory  
Affairs

**Docket No.:** 20004-174-ER-25  
Record No. 17880

PUBLIC SERVICE COMMISSION  
APPROVED

EFFECTIVE: **April 1, 2026**

DOCKET NO. **20004-174-ER-25**  
STATE OF WYOMING



# Montana-Dakota Utilities Co.

400 N 4<sup>th</sup> Street  
Bismarck, ND 58501

## State of Wyoming Electric Rate Schedule

W.P.S.C. Tariff No. 2  
Original Sheet No. 80.2

### PARALLEL GENERATION GENERAL RULES Rate 59

Page 3 of 3

13. All necessary rights-of-way and easements to install, operate, maintain, replace and remove utility facilities, including adequate access rights, are to be furnished by the owner of the qualifying facility on owner's property.
14. The metering shall be adequate to measure energy, or energy and capacity, from the qualifying facility to the utility, from the utility to the qualifying facility, and, if necessary, adequate to determine the time at which energy is transferred from one party to another.
15. Interconnection costs shall be on an actual cost basis for all costs that are in excess of the costs that the utility would have incurred if it had not engaged in interconnected operations, but instead generated or purchased the same amount of energy or capacity. The owner of a qualifying facility is allowed up to one year to reimburse the utility for these costs.
16. Where no changes to the utility system are necessary except for installing additional metering, an average interconnection fee for qualifying facilities of 100 Kw or less shall apply.
17. The owner of a qualifying facility will indemnify and hold the utility harmless from all loss on account of injury, death or damage to property caused by the qualifying facility unless the injury, death or damage is the direct result of the negligence of the utility.
18. Qualifying facilities shall be required to execute a contract that specifies a one-year minimum term and describes the responsibilities, liabilities, ownership of equipment, and location.
19. The owner of a qualifying facility shall obtain and maintain general liability insurance in the amount of \$500,000 for each occurrence or as determined by the Wyoming Public Service Commission.

**Date Filed:** June 30, 2025

**Effective Date:** Service rendered on and  
after April 1, 2026

**Issued By:** Travis R. Jacobson  
Vice President – Regulatory  
Affairs

**Docket No.:** 20004-174-ER-25  
Record No. 17880

PUBLIC SERVICE COMMISSION  
APPROVED  
EFFECTIVE: **April 1, 2026**  
DOCKET NO. **20004-174-ER-25**  
STATE OF WYOMING